



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

May 18, 2023

Mark Sullivan
North Warren CSD
6110 State Route 8
Chestertown, NY 12817

TEL: (518) 494-3015

Work Order No: 230503110

PO#: A23-00351

RE:

PK-12 School

Adirondack Environmental Services, Inc received 45 samples on 5/4/2023 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

A handwritten signature in black ink that reads "Tara Daniels". The signature is written in a cursive style with a large initial "T".

Tara Daniels
Laboratory Director

North Warren CSD

Date: 18-May-23

PK-12 School

Lab WorkOrder: 230503110

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers: ND : Not Detected at reporting limit	C: CCV below acceptable Limits
J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
H: Hold time exceeded	Z: Duplication outside acceptable limits
N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 18-May-23

CLIENT: North Warren CSD

LabWork Order: 230503110

Project:

PK-12 School

PO#: A23-00351

Lab SampleID: 230503110-001

Collection Date: 5/3/2023 5:40:00 AM

Client Sample ID: A101-10 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.4	1.0		µg/L	1	5/17/2023 6:51:42 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-002

Collection Date: 5/3/2023 5:38:00 AM

Client Sample ID: A103-09 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.3	1.0		µg/L	1	5/17/2023 7:02:27 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-003

Collection Date: 5/3/2023 5:36:00 AM

Client Sample ID: A105-08 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	3.2	1.0		µg/L	1	5/17/2023 7:06:01 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-004

Collection Date: 5/3/2023 5:35:00 AM

Client Sample ID: A107-07 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.2	1.0		µg/L	1	5/17/2023 7:09:36 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-005

Collection Date: 5/3/2023 5:32:00 AM

Client Sample ID: A108-05 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	2.3	1.0		µg/L	1	5/17/2023 7:13:12 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 18-May-23

CLIENT: North Warren CSD

LabWork Order: 230503110

Project:

PK-12 School

PO#: A23-00351

Lab SampleID: 230503110-006

Collection Date: 5/3/2023 5:31:00 AM

Client Sample ID: A109-04 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.9	1.0		µg/L	1	5/17/2023 7:16:47 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-007

Collection Date: 5/3/2023 5:27:00 AM

Client Sample ID: A112-03 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	5.1	1.0		µg/L	1	5/17/2023 7:27:32 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-008

Collection Date: 5/3/2023 5:26:00 AM

Client Sample ID: A113-02 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	3.6	1.0		µg/L	1	5/17/2023 7:31:09 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-009

Collection Date: 5/3/2023 5:24:00 AM

Client Sample ID: A114-01 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	2.5	1.0		µg/L	1	5/17/2023 7:34:45 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-010

Collection Date: 5/3/2023 5:47:00 AM

Client Sample ID: A120-15 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	3.1	1.0		µg/L	1	5/17/2023 7:38:20 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 18-May-23

CLIENT: North Warren CSD

LabWork Order: 230503110

Project:

PK-12 School

PO#: A23-00351

Lab SampleID: 230503110-011

Collection Date: 5/3/2023 5:49:00 AM

Client Sample ID: A121-16 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	2.6	1.0		µg/L	1	5/17/2023 7:41:55 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-012

Collection Date: 5/3/2023 5:50:00 AM

Client Sample ID: A122-17 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	2.3	1.0		µg/L	1	5/17/2023 7:52:41 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-013

Collection Date: 5/3/2023 5:51:00 AM

Client Sample ID: A123-18 EHO Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.8	1.0		µg/L	1	5/17/2023 7:56:16 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-014

Collection Date: 5/3/2023 5:53:00 AM

Client Sample ID: A124-19 HSHO Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	2.9	1.0		µg/L	1	5/17/2023 7:59:51 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-015

Collection Date: 5/3/2023 5:58:00 AM

Client Sample ID: B140-22 R Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	3.0	1.0		µg/L	1	5/17/2023 8:10:36 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 18-May-23

CLIENT: North Warren CSD

LabWork Order: 230503110

Project:

PK-12 School

PO#: A23-00351

Lab SampleID: 230503110-016

Collection Date: 5/3/2023 5:58:00 AM

Client Sample ID: B140-23 L Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	2.9	1.0		µg/L	1	5/17/2023 8:14:11 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-017

Collection Date: 5/3/2023 6:00:00 AM

Client Sample ID: C143-24 Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.0	1.0		µg/L	1	5/17/2023 8:17:47 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-018

Collection Date: 5/3/2023 6:02:00 AM

Client Sample ID: C145-25 Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.4	1.0		µg/L	1	5/17/2023 8:21:23 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-019

Collection Date: 5/3/2023 5:44:00 AM

Client Sample ID: K1-13 Kitchen Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.3	1.0		µg/L	1	5/17/2023 8:25:00 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-020

Collection Date: 5/3/2023 5:43:00 AM

Client Sample ID: K4-14 Steam Kettle

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.3	1.0		µg/L	1	5/17/2023 8:28:35 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 18-May-23

CLIENT: North Warren CSD

LabWork Order: 230503110

Project:

PK-12 School

PO#: A23-00351

Lab SampleID: 230503110-021

Collection Date: 5/3/2023 5:45:00 AM

Client Sample ID: K2-12 Ice

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	2.7	1.0		µg/L	1	5/17/2023 8:39:22 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-022

Collection Date: 5/3/2023 5:45:00 AM

Client Sample ID: K3-11 Kitchen Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	3.4	1.0		µg/L	1	5/17/2023 8:57:17 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-023

Collection Date: 5/3/2023 6:32:00 AM

Client Sample ID: D201-45 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	2.0	1.0		µg/L	1	5/17/2023 9:00:53 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-024

Collection Date: 5/3/2023 6:31:00 AM

Client Sample ID: D202-44 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	2.0	1.0		µg/L	1	5/17/2023 9:04:29 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-025

Collection Date: 5/3/2023 6:30:00 AM

Client Sample ID: D205-43 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	2.6	1.0		µg/L	1	5/17/2023 9:08:05 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 18-May-23

CLIENT: North Warren CSD

LabWork Order: 230503110

Project:

PK-12 School

PO#: A23-00351

Lab SampleID: 230503110-026

Collection Date: 5/3/2023 6:29:00 AM

Client Sample ID: D206-42 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.7	1.0		µg/L	1	5/17/2023 9:11:41 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-027

Collection Date: 5/3/2023 6:28:00 AM

Client Sample ID: D207-40 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	7.8	1.0		µg/L	1	5/17/2023 9:15:17 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-028

Collection Date: 5/3/2023 6:27:00 AM

Client Sample ID: D208-39 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	4.9	1.0		µg/L	1	5/17/2023 9:18:53 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-029

Collection Date: 5/3/2023 6:26:00 AM

Client Sample ID: D209-38 R Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	6.6	1.0		µg/L	1	5/17/2023 9:22:29 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-030

Collection Date: 5/3/2023 6:26:00 AM

Client Sample ID: D209-37 L Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	3.3	1.0		µg/L	1	5/17/2023 9:26:04 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 18-May-23

CLIENT: North Warren CSD

LabWork Order: 230503110

Project:

PK-12 School

PO#: A23-00351

Lab SampleID: 230503110-031

Collection Date: 5/3/2023 6:24:00 AM

Client Sample ID: D212-36 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	8.3	1.0		µg/L	1	5/17/2023 9:36:49 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-032

Collection Date: 5/3/2023 6:23:00 AM

Client Sample ID: D214-35 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	3.1	1.0		µg/L	1	5/17/2023 9:47:37 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-033

Collection Date: 5/3/2023 6:22:00 AM

Client Sample ID: D215-34 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	3.1	1.0		µg/L	1	5/17/2023 9:51:13 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-034

Collection Date: 5/3/2023 6:21:00 AM

Client Sample ID: D216-33 CRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	5.7	1.0		µg/L	1	5/17/2023 9:54:48 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 230503110-035

Collection Date: 5/3/2023 6:19:00 AM

Client Sample ID: D217-32 Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.1	1.0		µg/L	1	5/17/2023 9:58:24 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 18-May-23

CLIENT: North Warren CSD

LabWork Order: 230503110

Project:

PK-12 School

PO#: A23-00351

Lab SampleID: 230503110-036

Collection Date: 5/3/2023 6:12:00 AM

Client Sample ID: D233-28 Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.8	1.0		µg/L	1	5/17/2023 10:02:01 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 230503110-037

Collection Date: 5/3/2023 6:13:00 AM

Client Sample ID: D233-29 Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	4.7	1.0		µg/L	1	5/17/2023 10:05:37 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 230503110-038

Collection Date: 5/3/2023 6:13:00 AM

Client Sample ID: D233-30 Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	1.1	1.0		µg/L	1	5/17/2023 10:09:13 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 230503110-039

Collection Date: 5/3/2023 6:14:00 AM

Client Sample ID: D233-31 Sink

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	4.7	1.0		µg/L	1	5/17/2023 10:19:59 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 230503110-040

Collection Date: 5/3/2023 5:54:00 AM

Client Sample ID: BFS1-20 BFS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	ND	1.0		µg/L	1	5/17/2023 10:23:35 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 18-May-23

CLIENT: North Warren CSD

LabWork Order: 230503110

Project:

PK-12 School

PO#: A23-00351

Lab SampleID: 230503110-041

Collection Date: 5/3/2023 5:33:00 AM

Client Sample ID: BFS2-06 BFS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	ND	1.0		µg/L	1	5/17/2023 10:34:23 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 230503110-042

Collection Date: 5/3/2023 6:28:00 AM

Client Sample ID: BFS3-41 BFS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	ND	1.0		µg/L	1	5/17/2023 10:45:11 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 230503110-043

Collection Date: 5/3/2023 6:05:00 AM

Client Sample ID: BFS4-26 BFS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	ND	1.0		µg/L	1	5/17/2023 10:48:47 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 230503110-044

Collection Date: 5/3/2023 6:08:00 AM

Client Sample ID: BFS5-27 BFS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	ND	1.0		µg/L	1	5/17/2023 10:52:24 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 230503110-045

Collection Date: 5/3/2023 5:56:00 AM

Client Sample ID: BFS6-21 BFS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 5/4/2023)

Lead	ND	1.0		µg/L	1	5/17/2023 11:03:10 PM
------	----	-----	--	------	---	-----------------------



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

8/03

AES Work Order#: 230503110

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>North Warren CSD</u>	Address: <u>6110 State Route 8 Chester town, NY 12817</u>	
Send Report to: <u>Mark Sullivan</u>	Project Name (Location): <u>PK-12 School</u>	Samplers Name: <u>Mark Sullivan</u>
Client Phone #: <u>518932-4182</u>	Client PO #: <u>A23-00351</u>	Samplers Signature: <u>Mark Sullivan</u>
Client Email: <u>See remarks</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	A101-10 CRS	5-3-23	5:40	DW	✓		1	NA	Lead
002	A103-09 CRS	5-3-23	5:38	DW	✓		1	NA	Lead
003	A105-08 CRS	5-3-23	5:36	DW	✓		1	NA	Lead
004	A107-07 CRS	5-3-23	5:35	DW	✓		1	NA	Lead
005	A108-05 CRS	5-3-23	5:32	DW	✓		1	NA	Lead
006	A109-04 CRS	5-3-23	5:31	DW	✓		1	NA	Lead
007	A112-03 CRS	5-3-23	5:27	DW	✓		1	NA	Lead
008	A113-02 CRS	5-3-23	5:26	DW	✓		1	NA	Lead
009	A114-01 CRS	5-3-23	5:24	DW	✓		1	NA	Lead
010	A120-15 CRS	5-3-23	5:47	DW	✓		1	NA	Lead
011	A121-16 CRS	5-3-23	5:49	DW	✓		1	NA	Lead
012	A122-17 CRS	5-3-23	5:50	DW	✓		1	NA	Lead
013	A123-18 EHO SINK	5-3-23	5:51	DW	✓		1	NA	Lead
014	A124-19 HSHO SINK	5-3-23	5:53	DW	✓		1	NA	Lead
015	B140-22 R SINK	5-3-23	5:58	DW	✓		1	NA	Lead

Shipment Arrived Via: FedEx UPS <input checked="" type="radio"/> Client <input checked="" type="radio"/> AES Other:	Special Instructions/Remarks: Email: <u>masullivan@northwarrencsd.org</u> DW - Drinking Water - Potable CRS - Class Room Sink
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <input checked="" type="radio"/> Standard NOTE: Samples received after 3:30pm are considered next business day.	

Relinquished by: (Signature) <u>Mark Sullivan 5-3-23</u>	Received by: (Signature) <u>Celia Moore</u>	Date <u>5/3/23</u>	Time <u>3:20</u>
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature) <u>Celia Moore</u>	Received for Laboratory by: <u>Craig Ford</u>	Date <u>5/3</u>	Time <u>5:47</u>

Sample Temperature Ambient ~ <input checked="" type="radio"/> Chilled ~ Chilling Begun Notes: <u>WZ</u>	Properly Preserved: <input checked="" type="radio"/> Y <input type="radio"/> N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other	Received Within Holding Times: <input checked="" type="radio"/> Y <input type="radio"/> N Notes:
Custody Seal Intact: <input checked="" type="radio"/> Y <input type="radio"/> N		
Bottles AES: <input checked="" type="radio"/> Y <input type="radio"/> N		



230503110



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

2 of 3

AES Work Order#: 230503110

COC Reference: _____

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>North Warren CSD</u>	Address: <u>6110 State Route 8 Chester town, NY 12817</u>	
Send Report to: <u>Mark Sullivan</u>	Project Name (Location): <u>PK-12 School</u>	Samplers Name: <u>Mark Sullivan</u>
Client Phone #: <u>518932-4182</u>	Client PO #: <u>A23-00351</u>	Samplers Signature: <u>Mark Sullivan</u>
Client Email: <u>See remarks</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
016	B140-23 L sink	5-3-23	5:58	DW		✓	1	NA	Lead
017	C143-24 sink	5-3-23	6:00	DW		✓	1	NA	Lead
018	C145-25 sink	5-3-23	6:02	DW		✓	1	NA	Lead
019	K1-13 kitchen sink	5-3-23	5:44	DW		✓	1	NA	Lead
020	K4-14 K4-14 STEAM KETTLE	5-3-23	5:43	DW		✓	1	NA	Lead
021	K2-12 ICE	5-3-23	5:45	DW		✓	1	NA	Lead
022	K3-11 Kitchen Sink	5-3-23	5:45	DW		✓	1	NA	Lead
023	D201-45 CRS	5-3-23	6:32	DW		✓	1	NA	Lead
024	D202-44 CRS	5-3-23	6:31	DW		✓	1	NA	Lead
025	D205-43 CRS	5-3-23	6:30	DW		✓	1	NA	Lead
026	D206-42 CRS	5-3-23	6:29	DW		✓	1	NA	Lead
027	D207-40 CRS	5-3-23	6:28	DW		✓	1	NA	Lead
028	D208-39 CRS	5-3-23	6:27	DW		✓	1	NA	Lead
029	D209-38 R sink	5-3-23	6:26	DW		✓	1	NA	Lead
030	D209-37 L sink	5-3-23	6:26	DW		✓	1	NA	Lead

Shipment Arrived Via: FedEx UPS <input type="radio"/> Client <input checked="" type="radio"/> AES Other: _____	Special Instructions/Remarks: Email: <u>masullivan@northwarrencsd.org</u> <u>DW - Drinking Water - Potable</u> <u>CRS - Classroom Sink</u>
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <input checked="" type="radio"/> Standard NOTE: Samples received after 3:30pm are considered next business day.	

Relinquished by: (Signature) <u>Mark Sullivan</u> 5-3-23	Received by: (Signature) <u>Celi Mee</u>	Date 5/3/23	Time 3:20
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Time _____
Relinquished by: (Signature) <u>Celi Mee</u>	Received for Laboratory by: <u>Craig</u>	Date 5/3	Time 5:42

Sample Temperature Ambient ~ <u>Chilled</u> ~ Chilling Begun Notes: <u>402</u>	Properly Preserved: <input checked="" type="radio"/> Y <input type="radio"/> N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: <input checked="" type="radio"/> Y <input type="radio"/> N Notes: _____
Custody Seal Intact: <input checked="" type="radio"/> Y <input type="radio"/> N		
Bottles AES: <input checked="" type="radio"/> Y <input type="radio"/> N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

3 of 3

AES Work Order#: 230503110

COC Reference: _____

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>North Warren CSD</u>	Address: <u>6110 State Route 8 Chester town, NY 12817</u>	
Send Report to: <u>Mark Sullivan</u>	Project Name (Location): <u>PK-12 School</u>	Samplers Name: <u>Mark Sullivan</u>
Client Phone #: <u>518932-4182</u>	Client PO #: <u>A23-00351</u>	Samplers Signature: <u>Mark Sullivan</u>
Client Email: <u>See remarks</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
031	D212-36 CRS	5-3-23	6:24	DW	✓		1	NA	Lead
032	D214-35 CRS	5-3-23	6:23	DW	✓		1	NA	Lead
033	D215-34 CRS	5-3-23	6:22	DW	✓		1	NA	Lead
034	D216-33 CRS	5-3-23	6:21	DW	✓		1	NA	Lead
035	D217-32 CRS Sink	5-3-23	6:19	DW	✓		1	NA	Lead
036	D233-28 Sink	5-3-23	6:12	DW	✓		1	NA	Lead
037	D233-29 Sink	5-3-23	6:13	DW	✓		1	NA	Lead
038	D233-30 Sink	5-3-23	6:13	DW	✓		1	NA	Lead
039	D233-31 Sink	5-3-23	6:14	DW	✓		1	NA	Lead
040	BFS1-20 BFS	5-3-23	5:54	DW	✓		1	NA	Lead
041	BFS2-26 BFS	5-3-23	5:33	DW	✓		1	NA	Lead
042	BFS3-41 BFS	5-3-23	6:28	DW	✓		1	NA	Lead
043	BFS4-26 BFS	5-3-23	6:05	DW	✓		1	NA	Lead
044	BFS5-27 BFS	5-3-23	6:08	DW	✓		1	NA	Lead
045	BFS6-21 BFS	5-3-23	5:56	DW	✓		1	NA	Lead

Shipment Arrived Via: FedEx UPS <input checked="" type="radio"/> Client <input checked="" type="radio"/> AES Other: _____	Special Instructions/Remarks: <u>Email: masullivan@northwarrencsd.org</u> <u>DW - Drinking Water - Potable</u> <u>CRS Class Room Sink</u> <u>BFS Bottle Filling Station</u>
--	---

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature) <u>Mark Sullivan</u> 5-3-23	Received by: (Signature) <u>Celia [Signature]</u>	Date <u>5/3/23</u>	Time <u>3:20</u>
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature) <u>[Signature]</u>	Received for Laboratory by: <u>Craig [Signature]</u>	Date <u>5/3</u>	Time <u>5:42</u>

Sample Temperature Ambient ~ <u>Chilled</u> ~ Chilling Begun Notes: <u>W</u>	Properly Preserved: <input checked="" type="radio"/> Y <input checked="" type="radio"/> N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: <input checked="" type="radio"/> Y <input checked="" type="radio"/> N Notes:
Custody Seal Intact: <input checked="" type="radio"/> Y <input type="radio"/> N		
Bottles AES: <input checked="" type="radio"/> Y <input type="radio"/> N		



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.